

Part III. EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS**Table A.1. FINAL EFFLUENT LIMITATIONS AND MONITORING REQUIREMENTS FOR DISCHARGES FROM HSTS DESIGNED IN ACCORDANCE WITH OAC 3701-29, DISCHARGING TO WATERS OTHER THAN LAKE ERIE.**

During the period beginning on the effective date of this permit and lasting until the expiration date, the permittee is authorized to discharge in accordance with the following limitations and monitoring requirements.

<u>EFFLUENT CHARACTERISTICS</u>			<u>DISCHARGE LIMITATIONS</u>		<u>MONITORING REQUIREMENTS</u> (3)	
Reporting Code	Units	Parameter	Concentration 30 Day	Daily	Meas. Frequency	Sample Type
00056	GPD	Flow Rate	-	-	1/year	24HrTot.Est.
00530	mg/l	Total Suspended Solids	-	18	1/year	Grab
00610	mg/l	Nitrogen,Ammonia(NH ₃)	-	2.0	1/year	Grab
		(summer)	-	4.5	1/year	Grab
		(winter)	-	15	1/year	Grab
80082	mg/l	CBOD ₅	-	523	1/year	Grab
31648	#/100ml	<i>E. coli</i>	-		1/year	Grab
00083	-	color, severity (1)	-	-	1/year	Estimate
01330	-	odor, severity (1)	-	-	1/year	Estimate
01335	-	turbidity, severity (1)	-	-	1/year	Estimate
00300	mg/l	Dissolved Oxygen	not less than 6.0 at any time		1/year	Grab
50060	mg/l	Chlorine,total residual (2)	not to exceed 0.038 at any time		1/year	Grab

(1) See Part IV, paragraph E.

(2) See Part IV, paragraph F.

(3) Additional operational monitoring requirements shall comply with those listed in OAC 3701-29 for all system components, including service contracts as applicable.